

COPYRIGHT AND OWNERSHIP OF THIS DRAWING IS VESTED IN DENNAMY REIDY ASSOCIATES. NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR STORED IN ANY RETRIEVAL SYSTEM OR ANY MANNER WITHOUT THE WRITTEN PERMISSION OF DENNAMY REIDY ASSOCIATES AS COPYRIGHT HOLDER EXCEPT AS AGREED FOR USE ON THE PROJECT FOR WHICH THE DOCUMENT WAS ORIGINALLY ISSUED. © ALL RIGHTS RESERVED BY THE LAW OF COPYRIGHT AND BY INTERNATIONAL COPYRIGHT CONVENTIONS ARE RESERVED TO DENNAMY REIDY ASSOCIATES. ©

NOTES:

1. USE FIGURED DIMENSIONS ONLY. DO NOT SCALE.
2. DRAWINGS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ENGINEERS, ARCHITECTS AND SERVICE ENGINEERS' DRAWINGS AND SPECIFICATIONS.

LEGEND:

- SITE BOUNDARY
- - - EXISTING WATERMAIN
- PROPOSED 100mm PE WATERMAIN
- PROPOSED 25mm PE WATERMAIN
- PROPOSED SLUICE VALVE
- PROPOSED AIR VALVE
- PROPOSED INVERT
- PROPOSED BOUNDARY BOX
- FINISHED FLOOR LEVEL

FFL=15.800

CONSTRUCTION REQUIREMENTS:

FOR WATERMAIN DETAILS PLEASE REFER TO IRISH WATER MAIN INFRASTRUCTURE STANDARD DETAILS - DOCUMENT NO. IW-CDS-5020-01.

FOR SLUICE VALVES, WATERMETERS, BOUNDARY BOXES AND INVERTS TO BE SPECIFIED IN WATERMAIN INFRASTRUCTURE STANDARD DETAILS - DOCUMENT NO. IW-CDS-5020-01.

ALLOW FOR THURST BLOCKS IN ACCORDANCE WITH IRISH WATER REQUIREMENTS AS SPECIFIED IN WASTEWATER INFRASTRUCTURE STANDARD DETAILS - DOCUMENT NO. IW-CDS-5020-01.

NOTES:

ALL SITE WATER SERVICES TO BE IN ACCORDANCE WITH CURRENT IRISH WATER INFRASTRUCTURE STANDARD DETAILS REFER TO DOCUMENT NO. IW-CDS-5020-01.

- STD-W-02- LAYOUT DETAILS.
- STD-W-03- HOUSE CONNECTION AND BOUNDARY BOX.
- STD-W-04-TO 10- PIPE CONNECTIONS.
- STD-W-11- SERVICES LAYOUT.
- STD-W-13- TRENCH AN BEDDING.
- STD-W-15- SLUICE VALVE.
- STD-W-16-19- HYDRANT.
- STD-W-22- AIR VALVE CHAMBER.
- STD-W-26- TRUST AND SUPPORT BLOCKS.
- STD-W-30- SCOUR CHAMBER AND HEADWALL.
- STD-W-30A-37- OTHER.

ALL WATER SERVICES INFRASTRUCTURES TO BE IN ACCORDANCE WITH IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE. IRISH WATER DOCUMENT NUMBER: IW-CDS-5020-03.

HYDRANTS TO COMPLY WITH BS 750. TYPE 2 SCREW DOWN TYPE. HYDRANT INDICATOR PLATES TO COMPLY WITH BS 3251.

REV.	DESCRIPTION	DATE	BY
A	SITE PLAN UPDATED	10.05.18	STR/RP

PLANNING

Dennamy Reidy Associates
CONSULTING CIVIL & STRUCTURAL ENGINEERS

THE PARK
LONG EDWARD ST.
DRUMCONDRA
DUBLIN 9

30 DRUMCONDRA RIA UPPER
DUBLIN 9

TEL: 01-4727820 (Dublin)
TEL: 081-416534 (Limerick)
email: mail@dennamyreidy.ie
website: www.dennamyreidy.ie

CLIENT: KERRY COUNTY COUNCIL,
CO. KERRY,
CONRYN,
KERRY.

PROJECT: HOUSING AT BALLOONAGH,
CO. KERRY

TITLE: PROPOSED WATERMAIN LAYOUT

DATE:	SCALE:	REV.
27.03.2018	AS SHOWN	A
DRAWN BY: STR	DRG. No. K138-03	
DESIGNED BY: STR		
CHECKED BY: RP		
APPROVED BY: RP	REVISIONS: A	

PROPOSED WATERMAIN LAYOUT
SCALE 1:250 @ A1

